

BHEL/ PSER-KOLKATA

**TENDER CHANGE NOTICE
(TCN-01 DATED 15/07/2011)**

TENDER NO.:- PSER:PUR:PMX:096(IX):040 Dtd.05/07/2011

FOR

**TENDER DOCUMENT FOR DESIGN, MANUFACTURING, TESTING AND SUPPLY OF TWO NOS.
33 KV/ 11 K V, 3.15 MVA POWER TRANSFORMER AT BHEL:PSER'S BARAUNI SITE**

FOLLOWING CLAUSES OF THE AFORESAID TENDER IS TO BE READ AS STATED BELOW:-

(1) Part – C (Technical Specification) of tender shall be as follows :-

2.0 FITTINGS

2.11 Drain cum sampling & filter valves shall be of Gun mental / MS instead of Brass.

- (2) Bidder shall submit GTP (General technical Particulars), QP (Quality plan), GA (General arrangement) drawing along with techno-commercial bid.**
- (3) Due date of submission is extended upto 26/07/2011 (15:00 HRS) & Techno-commercial bid shall be opened on 27/07/2011 (at 11:30 HRS)**

ALL OTHER TERMS & CONDITIONS OF THE ABOVE TENDER SHALL REMAIN UNCHANGED.

Bidders are requested to acknowledge this TCN-01 in their Techno-Commercial offer.

**Sr. ENGINEER / PUR
BHEL:PSER:KOLKATA**