Bharat Heavy Electricals Limited

(High Pressure Boiler Plant) Tiruchirappalli - 620014, TAMIL NADU, INDIA An ISO 9001

CAPITAL PURCHASE /MM/RAM

ENQUIRY - Corrigendum1

Phone: +91 431 257 7645 Fax: +91 431 252 07 19

Email: pgavictor@bheltry.co.in

Web: www.bhel.com/www.tenders.gov.in

NIT 25101

Enquiry Number: 2681500013

Enquiry Date: 04.11.15

Due date for submission of quotation: 03.12.15

You are requested to quote the Enquiry number date and due date in all your correspondences. This is only a request for quotation and not an order

ITEM DESCRIPTION: Heaterless/Ambient Waterbath type LPG Vaporizer and Mass Flow Meter

Details of Corrigendum

With respect to the reference enquiry, the following amendment is to be done.

Under PART-B, Point A(Brief Description of the System) and Sl.No.5, it is specified as "The LPG vapour pressure at the outlet of the vapouriser should be minimum 1.2 Kg/cm² and the delivered LPG vapour is to be free from liquid/residue carryover."

The corresponding point is to be revised as follows;

"The LPG vapour pressure at the outlet of the vapouriser should be minimum 1.6 Kg/cm² and vendor to specify the maximum LPG outlet pressure from the vapouriser and the delivered LPG vapour is to be free from liquid/residue carryover."

All other terms and conditions as published in the NIT_25101 remain unaltered

Confirmation of acceptance for BHEL commercial terms & conditions and Price Bid formats have been posted in BHEL Corporate web site www.bhel.com or from the Government tender website http://tenders.gov.in (public sector units > Bharat Heavy Electricals Limited page) under Enquiry reference "2681500013".

Tenders should reach us before 14:00 hours on the due date Tenders will be opened at 14:30 hours on the due date

Tenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present

Yours faithfully,