

Enquiry No. : 77/15/6205/RCD

Grizzly Feeder Screen Package for 5X800 MW Yadadri TPS

Sl. No.	Bidder's Query	BHEL Reply
<b>Technical</b>		
1	As per clause no.13D of doc. no. TSY/YTPS/SCREENS, is asking for Colored Mimic and Hard wired annunciation. As PLC / MCC is in BHEL's scope so it not clear where colored mimic and hard wired annunciation is required. We have not considered the same in our scope. Please confirm.	Noted. Coloured mimic and hardwired annunciation are not required for Grizzley feeder package. However, signals (to be decided during detailed engg) shall be made available by bidder at control JB(JB in bidder's scope) to provide annunciation at CHP DCS
2	As per clause no.17D, of doc. no. TSY/YTPS/SCREENS,is asking for Air conditioning. The design of Screens are for dusty atmosphere i.e. for crusher/ screen building etc. We reconfirm our Screens does not require any air conditioned atmosphere. The drives are mounted with screens and are dust proof type. The panels for screens are in central place i.e MCC room. The MCC rooms are beyond the scope of TRF. AC required for MCC rooms are excluded from TRF scope of supply. So, any air conditioning is excluded. Please confirm	Noted. AC is not required for Grizzley feeder package. However, VVVF panel in Bidder's scope (if required) for control shall be located in MCC building (MCC in BHEL's scope) and BHEL will provide AC for this building. Cabling between VVVF panel and motor shall be in Bidder's scope. Local air conditioners may be provided by bidder for VFD panel if panel is located near the equipment.
3		E&C of all electrical items shall be excluded from bidder's scope.
<b>Commercial Terms and Conditions</b>		
4	<p>Warranty - As per SCC warranty is 12 months from the date of successful completion of trial operation of the system. For better clarity we kindly request you to provide cut out dates for trial operation of screen as incoming belt conveyor system is not in our scope.</p> <p>We understand successful completion of trial operation of the screen means it may be no-load running trail at site.</p>	<p>The word "Warranty" mentioned in clause 15 of SCC shall be read as "Guarantee Period".</p> <p>Bidders to quote as per tender requirement. Please refer document put in the website as addendum for the meaning of trial run .</p>