

Enquiry No. : 77/15/6202/RCD

Paddle Feeder Package for 5X800 MW Yadadri TPS

Sl. No.	Bidder's Query	BHEL Reply
<b>Technical</b>		
1	As per clause no.13D, of doc. no. TSY/YTPS/PADDLE FEEDERS, is asking for VVVF drive panel. Please confirm.	VVVF if applicable for Paddle feeder package shall be in bidders scope
2	As per clause no.15D and sr. 1 and 2 of miscellaneous, is asking for erection work. As per NIT enquiry is based on supervision services. so, erection work to be excluded from vendor's scope. please confirm. Also, it is not clear how erection, testing and commissioning of tools and tackles, mandatory spares to be done. please clarify.	E& C against clause 15D is already excluded from bidder's scope. E&C not applicable for tools and tackles, mandatory spare.
3		E&C of all electrical items shall be excluded from bidder's scope.
<b>Commercial Terms and Conditions</b>		
4	<p>Warranty - As per SCC warranty is 12 months from the date of successful completion of trial operation of the system. For better clarity we kindly request you to provide cut out dates for trial operation of paddle feeder as incoming feed systems are not in our scope.</p> <p>We understand successful completion of trial operation of the Paddle Feeder means it may be no-load running trail at site.</p>	<p>The word "Warranty" mentioned in clause 15 of SCC shall be read as "Guarantee Period".</p> <p>Bidders to quote as per tender requirement. Please refer document put in the website as addendum for the meaning of trial run .</p>