



**COMBINED OPEN TENDER ENQUIRY FOR STATION LIGHTING SYSTEM OF 2 X
500MW NEW NEYVELI TPP (TG PKG.) and 2X500MW NEW NEYVELI TPP (SG
PKG.)**

Ref No. : E-4582/2014

Date: 21.10.14

CORRIGENDUM/ ADDENDUM-1

Subject: Considering change in clause 8.6 of Section-C of Technical Specification

Our Ref : TENDER ENQUIRY NO: E-4582/2014, DTD-13.10.14
Package : STATION LIGHTING SYSTEM
Project : 2 X 500MW NEW NEYVELI TPP (TG PKG.) & 2X500MW NEW NEYVELI TPP (SG PKG.)

This is in reference to the above Tender Enquiry No. : E-4582/2014, DTD-13.10.14, please note that *The DC fixtures shall be suitable for 2 X 18 W CFL instead of 1 X 18 W CFL. Thus, the clause 8.6 of Section-C of Technical Specification for Station Lighting System may please be read as:*

<i>Instead of</i>	<i>Read As</i>
<p>8.6 Following type of fixtures shall be used for Emergency DC lighting.</p> <p>FC07: 1 x 18 W Fluorescent, industrial box type base and vitreous enamelled side reflectors operating on 220V DC input supply.</p> <p>FC33: 1 x 18 W Fluorescent, decorative, recessed type with mirror optic reflector operating on 220V DC input supply.</p> <p>FC34: 1 x 18W Fluorescent, dust proof, totally enclosed type with sheet steel housing operating on 220V DC input supply.</p>	<p>8.6 Following type of fixtures shall be used for Emergency DC lighting.</p> <p>FC07: 2 x 18 W Fluorescent, industrial box type base and vitreous enamelled side reflectors operating on 220V DC input supply.</p> <p>FC33: 2 x 18 W Fluorescent, decorative, recessed type with mirror optic reflector operating on 220V DC input supply.</p> <p>FC34: 2 x 18W Fluorescent, dust proof, totally enclosed type with sheet steel housing operating on 220V DC input supply.</p>

Thanking You,

With Regards,

For and on behalf of

Naina Singh (Dy. Mgr./PG-II-2)

Power Project Engineering Institute Building

HRD & ESI Complex Plot No. 25, Sector -16 A,

BHEL-PEM, Noida-201301 (U.P.)

Tel No. 0120-4368762

Please reply to

Naina Singh (Dy. Mgr./PG-II-2)

Power Project Engineering Institute Building

HRD & ESI Complex Plot No. 25, Sector -16 A,

BHEL-PEM, Noida-201301 (U.P.)

Tel No. 0120-4368762