

**TENDER ENQUIRY FOR VIS FOR FAN FOUNDATION FOR 1X800MW TANGEDCO NORTH  
CHENNAI STG.III**

Date: 31.03.2017

**CORRIGENDA-2**

Tender Enquiry no.: PE/PG/TAN/E-5509/2016 Dated 06.03.17


<b>DUE DATE</b>
<b>11-APRIL-2017</b>
<b>10:00 AM IST</b>

It is clarified that vibration isolation efficiency shall be at least 90% as mentioned in clause no 2.3 of the technical specification. Accordingly, “... not more than 5 % of dynamic loads...” mentioned in Clause no 1.03 iv) shall be read as “... not more than 10% of dynamic loads...”

It may please be noted that bid submission due date for tender enquiry no. PE/PG/TAN/E-5509/2016 dated 06.03.17 floated for “VIS FOR FAN FOUNDATION” package for subject project has been extended till 11.04.2017 (10.00 AM). Techno-commercial bid shall be opened on 11.04.2017 (11.00 AM).

NO FURTHER EXTENSION FOR BID SUBMISSION SHALL BE GRANTED FOR THIS TENDER.

With Regards,  
For & on behalf of BHEL



(Gaurav Gupta)  
Sr Engineer/PG-II-1/ BHEL-PEM

Please reply to:

**Gaurav Gupta, Sr Engineer**  
**PG-II-1**

Power Project Engineering Institute Building  
HRD & ESI Complex Plot No. 25, Sector -16 A,  
BHEL-PEM,Noida-201301 (U.P.)

Tel No. 0120-4368685/4368519, Fax: 0120-4329106