

Ref : BHE/PW/PUR/RGMT-TI-CLD-LINER/2095/Corg-01

Date: 30/04/2019

-----Page 1 of 2-----

To  
ALL BIDDERS,

**Sub: Corrigendum-01: Issuance of Clarifications, Amendment & Time Extension**

**Job:** Fabrication and Erection of Titanium cladded Chimney flue liners of twin flue RCC chimney at 2X800 MW NTPC Karimnagar SG Island Package.

**Reference:**

- E-Tender Spec No:** BHE/PW/PUR/RGMT-TI-CLD-LINER/2095

Bidders to kindly take note of the following:

**AA) ISSUE OF CLARIFICATIONS AGAINST THE QUERIES:**

Sl no	Reference clause of Tender Document	Existing provision	Bidder's query	BHEL's clarification
1	-	-	SIZES OF THE PLATES: Please confirm that BHEL will be issuing sizing of the plates as per drawings.	Please Refer Enclosed Annexure-I & II of the Corrigendum-01
2	-	-	EDGE PREPARATION: Please confirm that the edge preparation will be done by BHEL.	The plates will be issued to the contractor with edge Prepared, however rectification, if any, required for edge preparation has to be done by bidder with no extra cost.
3	-	-	ROLLING MARGIN: Please confirm that plates will have rolling margin.	Rolling has to be done as per approved rolling/bending Procedure provided along with tender documents .
4	-	-	Plate size for rolling, 26A & 26D percentage of weight to be clarified.	For Plate Size, please refer Annexure-I & II of the Corrigendum-01. Contract conditions Prevails for item 26A and 26D.
5	-	-	Please confirm whether Preheating & Post-heating is required.	Pre heating & post heating is not required as per current WPS. However any changes at later stage has to be accommodated by bidder with no extra cost.
6	-	-	UT percentage LS & CS for welding	NDT has to be carried out as per approved FQP.
7	-	-	E-tender price bid filling on online portal only	Tender Condition shall prevail.
8	-	-	Whether Bank Guarantee (BG) system generators is required from Bank	Tender Condition shall prevail.

Ref : BHE/PW/PUR/RGMT-TI-CLD-LINER/2095/Corg-01

Date: 30/04/2019

-----Page 2 of 2-----

**BB) AMENDMENT OF TENDER CONDITION:**

Sl no	Reference clause of Tender Document	Clause	Existing provision	Now Amended as
1	Cl. No. 2.17 of Vol-IC GCC	Price Variation Compensation	Cl. No. 2.17 of Vol-IC GCC Price Variation Compensation is applicable for this tender	Cl. No. 2.17 of Vol-IC GCC Price Variation Compensation is not applicable for this tender.
2	BOQ Item NO. 26 A, 26 B, 26 G  Of Part B of Vol-II Price bid, as per Chapter - XI of Vol-IA TCC	Payment Item Break Up	-	For BOQ Item No. 26A, 26B and 26 G of "BOQ", Part B of Vol-II Price bid, Payment shall be made as per break up mentioned hereunder: -  • 60% after Completion of fabrication and Pre-assembly.  • 40% after Completion of Erection, alignment and Welding.

**CC) Time Extension**

**Due date of offer submission being extended till 07/05/2019, 15.00 Hrs., Technical be shall be opened at 07/05/2019 16.00 Hrs.**

=====

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → [www.bhel.abcpurchase.com](http://www.bhel.abcpurchase.com)

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,  
Yours faithfully,

AGM (Purchase)

Corrigendum Ref. : BHE/PW/PUR/RGMT-TI-CLD-LINER/2095/Corg-01 , Dated 30/04/2019

" Annexure-I"

	Column Labels		
	U1	U2	Total Sum of No of Plates
Row Labels ( Dimensions in mm)	Sum of No of Plates	Sum of No of Plates	
TI CLAD PLATES (12X1900X6961)	54	54	108
TI CLAD PLATES (12X2500X6961)	265	266	531
TI CLAD PLATES (12X360X7004)	25	26	51
TI CLAD PLATES (18X1600X6965)	33	33	66
TI CLAD PLATES (18X2400X6965)	4	5	9
TI CLAD PLATES (18X2500X6965)	61	62	123
Grand Total	442	446	888

" Annexure-II"

Can Type	Can Total Height (mm)	Detail of (10+2) mm Thick plates (Length 6961 mm)		Detail of (16+2) mm Thick plates (Length 6965 mm)	
		Length of (10+2) mm Thick portion	Qty x Width required	Length of (16+2) mm Thick portion	Qty x Width required
A	7500	7500	3x2500 mm	0	-
B	7500	0	-	7500	3x2500 mm
C	7500	7500	3x2500 mm	0	-
D1	7670	5700	3x1900 mm	1600	1x1600 mm
		370 (ID 8906 mm) (Increased DIA for Expansion Joint)	1x370 mm (Length 7004 mm)	0	-
D2	5170	370 (ID 8906 mm) (Increased DIA for Expansion Joint)	1x370 mm (Length 7004 mm)	4800	3x1600 mm
E	4900	2500	1x2500 mm	2400	1x2400 mm
F	7500	0	-	7500	3x2500 mm
G	4100	2500	1x2500 mm	1600	1x1600 mm