

Ref: BHE/PW/PUR/ KNFGD-TEST-PILES/2354/Corg-02

Date: 12/01/2021

To,

ALL BIDDERS,

**Sub: Corrigendum-02: Issuance of Clarifications and additional documents.**

**Scope of Work:** CONSTRUCTION AND TESTING OF TEST PILES FOR NTPC KORBA STAGE-I (3X200 MW) + STAGE-II (3X500 MW) + STAGE-III (1X500 MW) THERMAL POWER PROJECT FGD PACKAGE, KORBA, CHHATTISGARH.

**References:**

1. **E-Tender Spec No:** BHE/PW/PUR/ KNFGD-TEST-PILES/2354
2. **Corrigendum-01** dated 11/01/2021 for tender due date extension from 11/01/2021 to 14/01/2021.

Bidders to kindly take note of the following:

**AA) ISSUANCE OF CLARIFICATIONS:**

Sl No	NIT Clause ref	Bidder's Query	BHEL Clarifications
1.	General	Safe load capacity of pile (600mm Dia and 760 MM Dia)	Bidders are requested to refer the "Annexure-A" of this corrigendum.
2.	General	Geo technical Report required	Preliminary Soil Report has been annexed along with this corrigendum as "Annexure-B".
3.	General	Location for muck Disposal (in Plant premises or outside Premises)	It is clarified that location of Muck disposal shall be inside the plant.
4.	General	Demobilization of Hydraulic RIG and other tools would be after competition of the test piles and not held till tests are done?	Demobilization of Hydraulic RIG and other Tools shall be done after successful completion of First Vertical load test and to the satisfaction of Construction manager. However, any rework and remobilization due to poor workmanship leading to Pile test failure, all risk lies with contractor without any extra cost to BHEL.

**BB) ISSUANCE OF ADDITIONAL DOCUMENTS:**

Additional technical specification documents has been issued as "Annexure-A" and "Annexure-B" along with this corrigendum, which shall be part of Volume-IE-Technical Specification and Plant Layout-2354.

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing. Bidders are requested to submit as a part of their offer, a copy of this corrigendum duly Digitally countersigned by the authorized signatory as a token of Bidder's unqualified acceptance of this corrigendum.

BIDDERS MAY PLEASE NOTE THAT SUBJECT TENDER IS E-TENDER AND THE OFFER IS TO BE SUBMITTED ONLY IN E-PROCUREMENT PORTAL → <https://eprocurebhel.co.in>

BIDDERS WHO HAVE ALREADY SUBMITTED THEIR OFFERS PRIOR TO ISSUANCE OF THIS CORRIGENDUM IN E-TENDER PORTAL ARE REQUIRED TO RE-SUBMIT THEIR OFFER AFTER TAKING COGNIZANCE OF THIS CORRIGENDUM.

Thanking you,  
Yours faithfully,

AGM (Purchase)

Enclosure:

- 1) Annexure-A: Additional technical specification documents (04 pages)
- 2) Annexure-B: Additional documents for Preliminary Soil Report (482 pages)