

Ref: BHE/PW/PUR/TENDHE-STG+MMS/1395/Corrigendum-06

Date 11/03/2015

To

ALL BIDDERS

Sub: Corrigendum-06: Clarification

JOB: RECEIPT OF EQUIPMENT/ MATERIAL AT SITE, UNLOADING, INSPECTION, VERIFICATION, REPORTING SHORTAGES / DAMAGES, STORAGE, UP-KEEPING DURING STORAGE, COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO SITE; ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION OF SURFACE CONDENSER, STEAM TURBINE, GENERATOR, PIPING, PUMPS & AUXILIARIES INCLUDING ELECTRICAL AND CONTROL & INSTRUMENTATION EQUIPMENTS / COMPONENTS, APPLICATION OF THERMAL INSULATION, FINAL PAINTING, ASSISTANCE FOR PG TEST ETC. AND HANDING OVER OF 2X40 MW STG SET AT TENDAHO NEW SUGAR FACTORY, AFAR REGIONAL STATE, ETHIOPIA

Bidders to kindly take note of the following:

AA) Clarification to the Queries of Bidder

Sl No	Description / Bidder's query	BHEL's clarification
1	Refer Clause 6.2.1.2 of Volume IB SCC regarding, sufficient numbers of wooden/concrete/steel sleepers for the job. How much quantity of concrete plate & Sleeper are required	In case sleepers are required, then requirement of sleepers will be less than 100
2	Refer Clause 4.1.4 of Volume IB SCC regarding, TIG Filler wire for Boiler and Filler wires for Electrodes for P91/T91 piping Who will supply the material & heating machines for TIG filler wire for TG and filler wires for electrodes for P-91/T91 piping	Contractor's scope

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

This letter is hosted as file titled "Corrigendum-06 (Clarification-1395)" against NIT-21278 in BHEL web page (www.bhel.com→Tender Notifications → View Corrigendum).

Thanking you,

Yours faithfully,

AGM (Purchase)