

BHARAT HEAVY ELECTRICALS, LIMITED
(MM TCB Division)

No: BHEL: MRX: E7293089 CORR: 01

Date: 27/06/2019

“CORRIGENDUM”

Reference Tender Notice issued vide MM /TCB/E7293089 Rev 00 dated 27/05/2019 by this Office of undersigned, the following changes in the Tender Notice are hereby notified through this Corrigendum for all concerned interested agencies /contractors/ firms.

- 1) **The Due Date for submission & Opening of tender is extended from 01/07/2019 to 11/07/2019.**
- 2) **Vendor Qualification Requirement (VQR) has been revised**
- 3) **Technical clarification/revision has been issued for technical specification.**


Rakesh Kumar


Sr. Engineer (MM TCB)

E-mail id: rakesh_kum@bhel.in

Phone: +91 755 250 5088

27/06/19
RAKESH KUMAR / Sr. Engineer
MM-TCB Division
BHEL, BHOPAL

ENQUIRY

		भारत हेवी इलेक्ट्रिकल लिमिटेड, भोपाल - ४६२०२२ (भारत) भारत हेवी इलेक्ट्रिकल लिमिटेड, पिप्लानि, भोपाल - ४६२०२२ (भारत)		ENQUIRY NO E7293089
BPC 0007		BHARAT HEAVY ELECTRICALS LIMITED, PIPLANI, BHOPAL - 462022 (INDIA) MATERIALS MANAGEMENT DIVISION		ENQUIRY DATE 27/05/19
TWO PART BID		TENDERS MANAGEMENT DIVISION		ENQUIRY DUE DATE 11/07/19
SUPP CODE 0		REV CD 3		
SUPP NAME AND ADDRESS		REV NO 1		
GUARANTEE CERTIFICATE		REV DATE 27/06/19		
TEST CERTIFICATE		NO OF CATY2 4		
INSTRUCTION BOOKLET		NO OF CATY3 4		
SAMPLE		NO OF ITEMS 4		
GATE PASS		INDENT NO		

TIN NO. 23573600001 | ECC NO. AA ACB4 146FXM009 | MPCT NO. HEL/05/01/0001/5/11/79
 PHONE: 01-755-2500100 (7 LINE) | FAX: 91-755-2500023 | WWW.BHEL.BHOPAL.COM

NOTE: QUOTE PRICE BOTH IN FIGURES & WORDS. IN CASE OF MISMATCH PRICE IN WORDS WILL BE VALID. QUOTATIONS NOT BEARING ENQUIRY NO AND DUE DATE LIABLE TO BE REJECTED.

SL NO	MATERIAL CODE	DESC	UNIT	ITEM QTY	QTY VR%	LOT NO	LOT QTY	DEST	DELIVERY DATE
1	TR4680167076	ONLINE DGA AS PER ITEM 1 OF ANNEXURE A	ST	60.000		1	60.000	206	31/12/19
2	TR4680167076	ONLINE DGA AS PER ITEM 2 OF ANNEXURE A	ST	20.000		1	20.000	206	31/12/19
3	TR4680167076	ONLINE DGA AS PER ITEM 3 OF ANNEXURE A	ST	60.000		1	60.000	206	31/12/19
4	TR4680167076	ONLINE DGA AS PER ITEM 4 OF ANNEXURE A	ST	10.000		1	10.000	206	31/12/19

REMARK: 1) THIS IS A RATE CONTRACT ENQUIRY INDICATING REQUIREMENT OF NEXT TWO YEAR. DELIVERY DATE MENTIONED IN THE ENQUIRY SHEET ARE TENTATIVE. MATERIAL WILL BE ORDERED AGAINST DIFFERENT PO'S AS PER SPECIFIC REQUIREMENT. 2) COMMERCIAL TERMS & CONDITIONS SHOULD BE STRICTLY ACCORDING TO THE ENCLOSED ANNEXURE TC 1A OR TC 1B. SUPPLIER NOT ADHERING TO THE T&C MENTIONED IN ANNEXURE TC 1A OR TC 1B IS LIABLE FOR REJECTION. A SIGNED COPY OF ANNEXURE IS TO BE ENCLOSED WITH OFFER. 3) THIS REV IS ISSUED TO EXTEND THE DUE DATE OF ENQUIRY AND REVISE THE VENDOR QUALIFICATION REQUIREMENT (VQR) & TECHNICAL SPECIFICATION ONLY.

DRAWING	N	PURCH SPEC	Y	CATALOGUE	N	Quality Surveillance	Pl: N	TWO PART BID	Y
---------	---	------------	---	-----------	---	----------------------	-------	--------------	---

NOTE: BHEL, BHOPAL'S Standard Terms & Conditions BP200102/MM5533 rev02 for imports and BP200102/MM5527 rev03 for indigeneous procurements form a part of this Enquiry. Bidders may obtain from us copies of these terms and conditions if not already available.

Note: During Bid Evaluation, No loading of price with regard to preferential payment of within 45 days will be made on vendore falling under MSMED ACT - OCT 06

SPECIAL REMARK:

Please submit your lowest quotation in sealed envelop essentially superscribed with ENQUIRY NO, DUE DATE AND PARTY'S NAME so as to reach at TENDER ROOM, GROUND FLOOR, ADM BUILDING, BHEL, PIPLANI BHOPAL-462022 by 11.00 am of due date.

1. This is only a request for Quotation & not an order.
 2. Small Scale industries should indicate SSI Regn. No. in Quotation/invoice.
 3. In case you are not making an offer against this Enquiry, we request you to post a regret letter.
 4. Indian vendors to please indicate GSTIN on their quotation.

NAME: SHRI RAKESH KUMAR
 DESG: SR. ENGINEER
 0755-2505088
 rakesh_kum@bhel.in

SIGN & SEAL: श्री. एच. ई. कुमर, भोपाल / BHEL, BHOPAL

VENDOR QUALIFICATION REQUIREMENTS: Online DGA

SL. No.	DESCRIPTION	VENDOR'S REMARKS (Y/N)
1.0	TECHNICAL:	
1.1	<p>Vendor or their principal should have supplied and commissioned minimum 3 sets (1 set each to 3 different Central or State Government Power utilities in India) of Online DGA system for Power Transformer/ Reactors in the past 5 years from the date of Techno-Commercial bid opening. Bidder to furnish the following supporting documents:</p> <p>(a) Valid un-priced PO copies and Commissioning certificate of same PO & item (duly signed by the customer) from 3 (Three) different Central or State Government Power utilities of India.</p> <p>This condition shall be applicable for each item 1, 2, 3 & 4 separately and should be met by furnishing supporting document for each item. Suitable linking document like invoice etc. to be furnished, if model number/ make is not indicated on PO/ commissioning certificate.</p>	
1.2	Vendor should be OEM or their authorized representative. Authorization letter from OEM (in the case of not directly quoted by OEM) for quoting their system and providing installation and commissioning at site and after sales services to be submitted along with bid.	
2.0	GENERAL:	
2.1	BHEL reserves the right to verify information and documents submitted by the vendor. In case the information is found to be false/ incorrect, the offer shall be rejected.	
2.2	New vendors who are not registered with BHEL, Bhopal to submit supplier registration form. This form is available on website www.bhel.com.	

Note-

1. Relevant documentary proof for above points must be furnished along with bid for scrutiny.
2. VQR shall be applicable for all suppliers.
3. All documents must be in Hindi or English only.
4. Sl. No. 2.2 is for information only.

AGM (MRX)
MISCC
Member

AGM (TRM-P)
MISCC
Member

AGM (QTR)
MISCC
Member

AGM (TRE)
MISCC
Chairman

R.D.S.
21/6/19

[Signature]
20/6/19

[Signature]

[Signature]
21/06/19

[Signature]
20/6/19

CLARIFICATION/ REVISION ON TECHNICAL REQUIREMENT AGAINST E7293089

Date – 21.06.2019

Clause	Existing	Amended
<p>Section 2 item 1 Point 9 last para</p>	<p>Bidder to include armoured multimode fiber optic cable in multiple of 25m with suitable ST connector at both end alongwith suitable converter/ adopter (if required) to communicate between DGA equipment and substation PC / Laptop in their scope of supply. Necessary FO port / suitable adopter at equipment end shall also be part of main DGA equipment.</p>	<p>Bidder to include armoured multimode fiber optic cable in multiple of 25m with suitable ST connector at both end alongwith suitable converter/ adopter (if required) to communicate between DGA equipment and substation PC / Laptop in their scope of supply. Necessary FO port / suitable adopter at equipment end shall also be part of main DGA equipment.</p> <p>Clarification – 500m FO cable, as indicated at point d against Item 1 & 2 is a optional item, which may be separately required from above.</p>
<p>Section 3 item 2 Point 7 last para</p>	<p>Bidder to include armoured multimode fiber optic cable in multiple of 25m with suitable ST connector at both end alongwith suitable converter/ adopter (if required) to communicate between DGA equipment and substation PC / Laptop in their scope of supply. Necessary FO port / suitable adopter at equipment end shall also be part of main DGA equipment.</p>	<p>Bidder to include armoured multimode fiber optic cable in multiple of 25m with suitable ST connector at both end alongwith suitable converter/ adopter (if required) to communicate between DGA equipment and substation PC / Laptop in their scope of supply. Necessary FO port / suitable adopter at equipment end shall also be part of main DGA equipment.</p> <p>Clarification – 500m FO cable, as indicated at point d against Item 1 & 2 is a optional item, which may be separately required from above.</p>
<p>Section 2 item 1 Point 2</p>	<p>Operating Principal - Photo acoustic spectroscopy (PAS) or Gas chromatography (GC) with thermal conductivity detector (TCD)/ Flame ionization detector (FID) method The analyzer should measure (not calculate) all above gases.</p>	<p>Operating Principal - Photo acoustic spectroscopy (PAS) or Gas chromatography (GC) with thermal conductivity detector (TCD)/ Flame ionization detector (FID) method / Non-Dispersive NIR (Near Infra-Red) Spectroscopy The analyzer should measure (not calculate) all above gases.</p>

ADP
11.06.19

52