

Technical Specification for Enquiry No. E-7130557

1. 132 KV LIGHTENING ARRESTER:

DISCRIPTION:

132 KV 10 KA RATED (DISCHARGE CLASS-3) METOVAR METAL OXIDE GAPLESS SURGE ARRESTER HERMETACALLY SEALED IN A PORCELAIN CONTAINER HAVING PRESSURE RELEASE ARRANGEMENT AT BOTH END WITH A LINE TERMINAL CONNECTOR FOR SOLID BY EARTHED NEUTRAL SYSTEM TO BE USED ON A NOMINAL VOLTAGE OF 132 KV AND MAXIMUM VOLTAGE 145 KV FOR AN MCOV OF 112 KV RMS WITH INSULATING BASE, SURGE MONITOR & CONNECTING LEAD AND TERMINAL CONNECTOR CREEPAGE DISTANCE-25 MM/KV.

- A. **QTY.**:- 03 nos.
- B. **Delivery Required in Jan-14**
- c. Erection & Commissioning is not required.
- D. CEBG/EMD is not required for above item.