

## **List of clarifications for the Enq B7B1T93440**

- 1) Annex-1: Clause 2.7.0. Motor shall be as per IE3 class. Refer Annex-5 and Annex-16
- 2) Annex-1: Motor sizing max of the BkW as per clause 3.1.12 and 3.1.13
- 3) Annex-1 Line mounted and pump in built relief valve both to be considered.
- 4) Annex-2: Note 2- Leak proof test for 30 mins.
- 5) Annex-4 : Duplex filter with 3 way valve to be considered.
- 6) Annex-6: Tank dimension In line with Annex-2
- 7) Annex-8: Operating temperature 50 Deg C.
- 8) Annex-13 : Lube oil accumulator capacity 2x55 Lts.
- 9) Annex-13: MOC of accumulator shall be CS.
- 10) Annex-14 : Top mounted level gauge acceptable. The location shall be such that maintenance is not obstructed.
- 11) List of documents to be submitted along with offer.

## ***List of documents to be submitted along with offer.***

- a) Annex-1
  - 1) Pump Data sheet
  - 2) Motor Data sheet
  - 3) Pump Assembly GAD
- b) Annex-2
  - 1) Lube Oil tank GAD with location of all connection marked.
- c) Annex-3
  - 1) Company stamp on Annex-3 painting schedule.
- d) Annex-4
  - 1) The flow diagram with all equipments rating, pipe size, instruments installed, tank capacity, Scope demarcation, type of valves, all connections etc shall be marked. Design pressure and temperature and flow through line shall be provided. (Note-Filter is Duplex type with 3-way valve, Accumulator is 2x55 Lts)
- e) Annex-5  
Company stamp on the document stating that all the points are confirmed.
- f) Annex-6  
Location of all the equipments with all dimensions from center line. The GAD of console shall be provided in plan, elevation and side view. Projection of all instruments TG, LG and PG shall be marked.
- g) Annex-7  
The detail as required in document to be filled. The MOC of all the parts shall be provided. GAD shall be provided.
- h) Annex-8  
Confirmation to all clause. Scope shall be filter with 30 way valve, elements 10 microns and 40 microns, Gasket and foundation bolt. GAD shall be provided.
- i) Annex-9  
Reference list of earlier supplied system of similar design. Parameters may be different.
- j) Annex-10  
Deviation list for all the Annex and TC64362-00 shall be submitted along the applicable clause.
- k) Annex-11  
In the technical bid please mention quoted in the remarks for the items offered. In the price bid fill in the unit prices as per the price schedule.
- l) Annex-12  
The signed and stamped copy shall be provided confirming to all the clause. In case of any deviation, same shall be clearly spelt in deviation list.
- m) Annex-13  
Accumulator of capacity 2x55 liters shall be supplied. Signed and stamped shall be provided. GAD shall be provided.

- n) Annex-14  
Signed and stamped shall be provided.
- o) Annex-15  
Confirmation to the quality plan shall be provided. Signed and stamped shall be provided.
- p) Annex-16  
Signed and stamped copy shall be provided.
- q) Spec TC64362-00  
Confirmation to all the clauses shall be provided. In case of any deviation, shall be spelt in deviation list.
- r) Supplier shall fill the PQC document a) Sub supplier questionnaire and pre-qualification criteria.