



# भारत हेवी इलेक्ट्रिकल्स लिमिटेड

( भारत सरकार का उपक्रम )

## BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

**TCN - 03**

Ref: PSER:RKL:SCT-C003:TCN-04

Date: 01-12-2022

Sub	Tender Change Notice (TCN)-04 .	
Job	Balance work for readiness of toilets in CHP MCC-2,AHP MCC-1,Silo MCC,HCS D Pump House,Silo Utility Building & other CHP AHP area at 1x250 MW NSPCL Rourkela PP-II Expansion, Odisha	
Ref	1.0	Tender no PSER:RKL:SCT-C003:22.
	2.0	BHEL's NIT, vide reference no PSER:RKL:SCT -C003:2469, Date: 12-11-2022.
	3.0	BHEL's NIT, vide reference no PSER:RKL:SCT -C003:TCN-01, Date: 21-11-2022.
	4.0	BHEL's NIT, vide reference no PSER:RKL:SCT -C003:TCN-02, Date: 22-11-2022.
	5.0	BHEL's NIT, vide reference no PSER:RKL:SCT -C003:TCN-03, Date: 28-11-2022.
	6.0	Other References, if any.

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

1. Sl No: 1(v) of NIT "DUE DATE & TIME OF OFFER SUBMISSION" is extended upto *Date: 03-12-2022, Time: 13-00 Hrs. IST*
2. Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
3. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

Mgr (SCT)

Encl: As Above.

पावर सेक्टर पूर्वी क्षेत्र ( मुख्यालय )

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 2339 8000

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
BHEL SITE OFFICE (1 x 250MW NSPCL ROURKELA TPP-III)  
ROURKELA STEEL PLANT, ROURKELA, DIST- SUNDARGARH,  
ODISHA, PIN-769011

Sub	No Deviation Certificate.	
Job	Balance work for readiness of toilets in CHP MCC-2,AHP MCC-1,Silo MCC,HCSD Pump House,Silo Utility Building & other CHP AHP area at 1x250 MW NSPCL Rourkela PP-II Expansion, Odisha	
Ref	1.0	Tender no PSER:RKL:SCT-C003:22.
	2.0	BHEL's NIT, vide reference no PSER:RKL:SCT -C003:2469, Date: 12-11-2022.
	3.0	BHEL's TCN-01, vide reference no PSER: RKL:SCT -C003:TCN-01 Date: 21.11.2022.
	4.0	BHEL's TCN-02, vide reference no PSER: RKL:SCT -C003:TCN-02 Date: 22.11.2022.
	5.0	BHEL's TCN-03, vide reference no PSER: RKL:SCT -C003:TCN-03 Date: 28.11.2022.
	6.0	BHEL's TCN-04, vide reference no PSER: RKL:SCT -C003:TCN-04 Date: 01.12.2022.
	7.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above-referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable).

In the event of observance of any deviation in any part of our offer later whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
representative of the bidder)

<p>पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय) POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALLAKE CITY, KOLKATA - 700 091 फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 033-2339 8000/ 2339 8236</p>
---

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALTLAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 033-2339 8000/ 2339 8236