



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 07

Ref: PSER:SCT:SNG-M1488:TCN-07

Date: 25/11/2013

Sub	Tender change notice (TCN) 07	
Job	Design, engineering, manufacturing, supply, supervision of erection & commissioning, Site Testing, Trial Run & Performance and Guarantee test of AC System including super vision of Site Store etc of Air Conditioning System Package for 2x600 MW Singareni Thermal Power Project, Andhra Pradesh	
Ref	1.0	Tender no PSER:SCT:SNG-M1488:13
	2.0	BHEL's NIT, vide ref no PSER:SCT:SNG-M1488:13 Dated 30/09/2013
	3.0	BHEL's TCN-01, vide ref no PSER:SCT:SNG-M1488:TCN-01 Dated 19/10/2013
	4.0	BHEL's TCN-02, vide ref no PSER:SCT:SNG-M1488:TCN-02 Dated 07/11/2013
	5.0	BHEL's TCN-03, vide ref no PSER:SCT:SNG-M1488:TCN-03 Dated 11/11/2013
	6.0	BHEL's TCN-04, vide ref no PSER:SCT:SNG-M1488:TCN-04 Dated 13/11/2013
	7.0	BHEL's TCN-05, vide ref no PSER:SCT:SNG-M1488:TCN-05 Dated 16/11/2013
	8.0	BHEL's TCN-06, vide ref no PSER:SCT:SNG-M1488:TCN-06 Dated 21/11/2013
	9.0	Other references (if any) .

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Due date of submission is extended from 25/11/2013 to 27/11/2013 at 15-00 Hrs.
- 2.0 Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached Format only .
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
For BHARAT HEAVY ELECTRICALS LTD

Sr. ENGR (SCT)

Encl

- 1.0 Revised 'No deviation certificate' format.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply, supervision of erection & commissioning, Site Testing , Trial Run & Performance and Guarantee test of AC System including super vision of Site Store etc of Air Conditioning System Package for 2x600 MW Singareni Thermal Power Project , Andhra Pradesh	
Ref	1.0	Tender no PSER:SCT:SNG-M1488:13
	2.0	BHEL's NIT, vide ref no PSER:SCT:SNG-M1488:13 Dated 30/09/2013
	3.0	BHEL's TCN-01 , vide ref no PSER:SCT:SNG-M1488:TCN-01 Dated 19/10/2013
	4.0	BHEL's TCN-02 , vide ref no PSER:SCT:SNG-M1488:TCN-02 Dated 07/11/2013
	5.0	BHEL's TCN-03 , vide ref no PSER:SCT:SNG-M1488:TCN-03 Dated 11/11/2013
	6.0	BHEL's TCN-04 , vide ref no PSER:SCT:SNG-M1488:TCN-04 Dated 13/11/2013
	7.0	BHEL's TCN-05 , vide ref no PSER:SCT:SNG-M1488:TCN-05 Dated 16/11/2013
	8.0	BHEL's TCN-06 , vide ref no PSER:SCT:SNG-M1488:TCN-06 Dated 21/11/2013
	9.0	BHEL's TCN-07 , vide ref no PSER:SCT:SNG-M1488:TCN-07 Dated 25/11/2013
	10.0	Other references (if any) .

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void .

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, Integrity Pact (If applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211798/ 1691