



Part A (Techno-Commercial Bid)

SECTION – I
QUALIFYING CRITERIA

The BIDDER has to compulsorily meet the following requirements to get Qualified for submitting the offer. The Vendor's Response Column has to be necessary filled in by the Bidder in the prescribed format as following:

S. No.	REQUIREMENTS	Bidder to Confirm / Specify
1	1.1 Only those vendors, who have supplied and commissioned at least ONE equipment of Rated or higher capacity as specified in Section IV and such equipment is presently working satisfactorily after commissioning (on the date of opening of Tender) should quote.	
	OR If such equipment has been supplied to BHEL, then it should be presently working satisfactorily after its commissioning and acceptance (on the date of opening of Tender) in BHEL.	
	1.2 Performance certificate from the customers (preferably 2) regarding satisfactory performance of machines supplied to them should be sent along with technical offer.	
2	BHEL reserves the right to verify the information provided by vendor. In case the information provided by vendor is found to be false/ incorrect, the offer shall be rejected.	
3	Bids should be submitted by OEMs of DG only (OEM licence may be submitted along with offer)	

SIGNATURE & SEAL OF BIDDER

**Part A(Techno-Commercial Bid)****SECTION – I I**

The BIDDER has to give complete details against each clause in the table given below, with additional sheets those may be attached (giving clear reference number) to furnish and cover the requisite details / documents.

Sl. No.	Particulars	Details to be submitted by Bidder
1	Profile of the Company bringing-out the years of Experience of the BIDDER in the field of manufacture, integration and supply of above mentioned machine	
2	Details on the Firm's Registration and the FINANCIAL STRENGTH of the COMPANY (Balance Sheet for the last 3 years) shall be submitted with the TECHNO-COMML.BID	
3	Indian/International Standards / Design Process Codes/testing method followed in Design and Manufacture of the Equipment.	(i) For Diesel Engine:- (ii) For Alternator:- (iii) For DG Set:-
4	Details on SERVICE-AFTER-SALES Set-Up in India including the Addresses of Agents / Service Centers in India.	
5	Any Additional Data to supplement the manufacturing capability of the BIDDER for the subject equipment	

SIGNATURE & SEAL OF BIDDER



Part A(Techno-Commercial Bid)

SECTION – III

The BIDDER has to comply with the following, for accepting the Technical Offer for Scrutiny by the Purchaser:

Sl.	REQUIREMENTS	Bidder's offer / comment
1	The BIDDER / VENDOR shall submit the offer in TWO PARTS- Technical & Commercial Bid (PART A) and Price Bid(Part B)	Vendor to Confirm/specify
2	The Offer shall contain a comparative statement of Technical Specifications given by BHEL and the Offer Details submitted by the Bidder, against each clause.	Vendor to Confirm/specify
3	The BIDDER / VENDOR shall assure a continuous supply of SPARES and SERVICE for Seven Years, from the date of commissioning of equipment at BHEL Works on chargeable basis.	Vendor to Confirm/specify
4	Two Parts Bid -The quotation is invited in Two Parts Bid i.e.:	Vendor to Confirm
	(1) Part A(Techno-Commercial Bid) - Section I, Part A-Section II , Part A- Section III & Part A-Section IV containing the Technical offer along with all Commercial Terms & Conditions mentioning clearly Delivery Terms, F.O.R CFP Rudrapur basis, Govt Duties(%), Levies(%), Taxes(%) etc. PLUS Unpriced copy Of Part-B (Price Bid) in separate sealed envelope and superscribing Techno- Commercial Bid and Price Bid on respective envelopes	Vendor to Confirm/specify
	(2) Part- B (Price -Bid) containing only Basic Price , Erection & Commissioning charges (if any) in separate sealed envelope superscribing on it Part- B (Price- Bid) &	Vendor to Confirm/specify
	(3) And then these two envelopes put inside a Third Big envelope super- scribing Price- Bid And Techno- Commercial Bid against Tender Notice No. ----- Dated----- Due for opening on Dated----- .Offers received in Single Bid or without Techno-commercial or Price bid will not be considered.	Vendor to Confirm/specify
5	The Techno- Commercial bid & Price- Bid are required to be submitted strictly as per our attached formats. Each page of the BHEL's formats are to be duly signed & stamped by the tenderers at the bottom of formats as a token of un-equivocal acceptance of the terms & conditions of the Tender. Price Bid of only those Bidders will be opened, whose Techno-Commercial Bid is accepted .	Vendor to Confirm
6	BHEL may go for Reverse Auction(RA) and decide L-1 based on the outcome of RA instead of opening price bids submitted by the bidders on its discretion	Vendor to Confirm
7	Soft copy if any, giving the salient features of the proposed machine with all sub-systems and auxiliaries, and /or showing live-demo of an existing and working machine of similar configuration and capacity may be provided.	Vendor to Confirm/specify
8	BIDDER has to indicate the Country of Origin for the supply of equipment.	Vendor to Confirm/specify
9	In case of preliminary qualification of the offer, on technical grounds, the BIDDER may be called for a detailed technical discussion on the original technical offer at BHEL Works, with a 07 days notice period.	Vendor to Confirm/specify
10	Any Govt. Taxes/ Duties/ Levies to be mentioned as a %age of A/B/C(ref. Part B-Price Bid):	
	(a)Custom Duty (if applicable) @ % of _____	Vendor to Confirm/specify
	(b)Excise Duty (if applicable) @ % of _____	Vendor to Confirm/specify
	(C) Cess on (if applicable) @% of _____	Vendor to Confirm/specify
	(d) Sales Tax against Form C @% of _____	Vendor to Confirm/specify
	(e) If Any other tax/ levy, mention name & % of _____	Vendor to Confirm/specify
	(f) Packing & forwarding charges,if any % of _____	Vendor to Confirm/specify
	(g) Freight in % of _____	Vendor to Confirm/specify
12	Delivery terms	FOR BHEL Rudrapur
13	Validity of offer	120 days from the date of opening of techno-commercial bid
14	Delivery period	Supply within 12 weeks from the date of placement of P.O. I&C within 03 weeks from date of supply.

SIGNATURE & SEAL OF BIDDER



Bharat Heavy Electricals Limited

Enquiry No. :

Due Date :

Supplier's Ref.:

Date :

Part A (Techno-Commercial Bid)

Section IV

Specification cum Compliance Certificate for 320 KVA SILENT DIESEL GENSET

Note:-

1. The 'Offered' Column and where applicable, the 'Deviations' & 'Remarks' Column of this format shall be filled in by the Bidder and submitted along with the offer. Inadequate / incomplete, ambiguous or unsustainable information against any of the clauses of the specifications / requirements shall be treated as non-compliance.

2. The offer and all documents enclosed with offer should be in English language only.

Name & Address of the supplier:

Telephone No.

Fax No.

e-mail :

Scope: Design, manufacture, supply, installation, testing & commissioning of 320 KVA SILENT DIESEL GENSET complying with the following specifications.

(Offers of bidders offering higher rating DG set against requirement of 320 KVA shall be acceptable subject to meeting other requirement of tender but without any additional weightage or consideration on price)

S No.	Description - BHEL's Requirement	Specified	Offered	Remarks
1.0	Application, Type & Rating	-		
1.1	Application	Indoor Service		
1.2	Type	Silent		
1.3	Make & model of DG	Vendor to specify		
1.4	Rating	320 KVA		Pls. also ref. 'Scope' of Section IV
1.5	The Generator Set should conform to latest CPCB-II norms & of Prime Power Rating having capability of running continuously in variable load condition for unlimited hours per year and should also have a 10% overload capacity of 1 hour in every 12 hours of operation.	Vendor to Confirm		
2.0	Technical specifications	-		
2.1	Diesel Engine (Compatible with latest CPCB norms)	Make: Cummins / Caterpillar / Volvopenta / Ashok Leyland / Perkins/ Kirloskar/ Mahindra Heavy Engines/ Mahindra-Navistar/Greeves Cotton (Party to confirm that proof of Engine sourced from original Manufacturer shall be submitted alongwith supply)		
2.1.1	No. of Cylinder & Arrangement	Vendor to specify		
2.1.2	Type	4-Stroke		
2.1.3	Capacity (bhp)	Vendor to specify		
2.1.4	Aspiration	Vendor to specify		
2.1.5	Governor/Class(Electronic/ Electronic backed by mechanical)	Vendor to specify		
2.1.6	Lubricating oil system capacity	Vendor to specify		
2.1.7	Coolant capacity (engine + radiator)	Vendor to specify		
2.1.8	AIR INTAKE SYSTEM	-		
	- Air intake manifold.	Vendor to Confirm/specify		
	- Air cleaner-Dry type	Vendor to Confirm		
	- Vacuum indicator.	Vendor to Confirm		
2.1.9	EXHAUST SYSTEM	-		
	- Optimised Turbocharger.	Vendor to Confirm		
	- S. S. Flexible connection.	Vendor to Confirm		
	- Exhaust manifold.	Vendor to Confirm		
	- Exhaust silencer – Residential type.	Vendor to Confirm		
2.1.10	Supply and Installation of Exhaust system from DG room to outside upto 1.5 mtr. above DG room rooftop as per CPCB/OHSAS norms including following:	Vendor to Confirm		
	- MS Black Pipe(after wards of silencer output), complete with Bends & Flanges - 10 mtrs.	Vendor to Confirm		
	- Thermal Insulation of exhaust piping with Mineral Wool 50mm thick, wire mesh and 26 gauge (approx) aluminum cladding within the DG Room - 06 mtrs. length	Vendor to Confirm		
	- MS Rigid support structure for DG set exhaust piping	Vendor to Confirm		
	- SS Bellows for end connection of exhaust piping with DG(as per requirement)	Vendor to Confirm		
2.1.11	COOLANT SYSTEM	-		
	- Engine water pump	Vendor to Confirm		
	- Radiator	Vendor to Confirm		



Bharat Heavy Electricals Limited

Enquiry No. :

Due Date :

Supplier's Ref.:

Date :

Part A (Techno-Commercial Bid)

Section IV

Specification cum Compliance Certificate for 320 KVA SILENT DIESEL GENSET

Note:-

1. The 'Offered' Column and where applicable, the 'Deviations' & 'Remarks' Column of this format shall be filled in by the Bidder and submitted along with the offer. Inadequate / incomplete, ambiguous or unsustainable information against any of the clauses of the specifications / requirements shall be treated as non-compliance.

2. The offer and all documents enclosed with offer should be in English language only.

Name & Address of the supplier:

Telephone No.

Fax No.

e-mail :

Scope: Design, manufacture, supply, installation, testing & commissioning of 320 KVA SILENT DIESEL GENSET complying with the following specifications.

(Offers of bidders offering higher rating DG set against requirement of 320 KVA shall be acceptable subject to meeting other requirement of tender but without any additional weightage or consideration on price)

S No.	Description - BHEL's Requirement	Specified	Offered	Remarks
2.1.12	LUBRICATING SYSTEM	-		
	- Oil Sump	Vendor to Confirm		
	- Engine mounted lub oil pump .	Vendor to Confirm		
	- lube oil filter.	Vendor to Confirm		
2.1.13	FUEL SYSTEM	-		
	- Fuel pump with Electronic Governor	Vendor to Confirm		
	- Injector	Vendor to Confirm		
	- 24V DC Solenoid Coil	Vendor to Confirm		
	- fuel filter system	Vendor to Confirm		
2.1.14	STARTING SYSTEM	-		
	- 24V DC Electric Starter	Vendor to Confirm		
	- 24V DC battery charging alternator	Vendor to Confirm		
	- Sealed Maintenance Free Dry Type Battery(IN FULLY CHARGED CONDITION) of suitable ratings for DG	Make: Amarraja/ Exide/Luminous/Okaya/Pulselite		
2.1.15	SAFETY CONTROLS	-		
	- Low lube oil pressure trip	Vendor to Confirm		
	- High Water/Coolant temperature trip.	Vendor to Confirm		
	- Overspeed stop	Vendor to Confirm		
2.2	Alternator	Make: Stamford / Leroy Somer/ Crompton Greaves/ Kirloskar/ BHEL-EML (Party to confirm that proof of Alternator sourced from original Manufacturer shall be submitted alongwith supply)		
2.2.1	Rated Generating Voltage	415V		
2.2.2	Output system	3 Phase 4 Wire		
2.2.3	Rated Frequency	50 Hz		
2.2.4	Speed	Vendor to specify		
2.2.5	Power Factor - 0.80 to Unity	Vendor to Confirm		
2.2.6	Class of Insulation - H	Vendor to Confirm		
2.2.7	Dynamically balanced Rotor	Vendor to Confirm		
2.2.8	Voltage regulation	+/- 2.5% between no load to full load		
2.2.9	Overload capacity(10% for one hour in any 12 hours of operation without exceeding temperature rise limits specified in when corrected to ambient temperature)	Vendor to Confirm		
2.2.10	Enclosures(Drip proof & screen protected IP-23)	Vendor to Confirm/specify		
2.2.11	The alternator shall be of self-excited, self regulated, self ventilated in brushless design, provided with suitable automatic voltage regulator and shall give rated output at NTP conditions.	Vendor to Confirm		
2.2.12	Horizontal foot mounted single bearing type	Vendor to Confirm		
2.3	Microprocessor Based integrated Generator Set Controller having following features:	Vendor to Confirm/specify		
2.3.1	Controls:	-		
	OFF/MANUAL/ AUTO switch	Vendor to Confirm		
	Emergency stop	Vendor to Confirm		



Bharat Heavy Electricals Limited

Enquiry No. :

Due Date :

Supplier's Ref.:

Date :

Part A (Techno-Commercial Bid)

Section IV

Specification cum Compliance Certificate for 320 KVA SILENT DIESEL GENSET

Note:-

1. The 'Offered' Column and where applicable, the 'Deviations' & 'Remarks' Column of this format shall be filled in by the Bidder and submitted along with the offer. Inadequate / incomplete, ambiguous or unsustainable information against any of the clauses of the specifications / requirements shall be treated as non-compliance.

2. The offer and all documents enclosed with offer should be in English language only.

Name & Address of the supplier:

Telephone No.

Fax No.

e-mail :

Scope: Design, manufacture, supply, installation, testing & commissioning of 320 KVA SILENT DIESEL GENSET complying with the following specifications.

(Offers of bidders offering higher rating DG set against requirement of 320 KVA shall be acceptable subject to meeting other requirement of tender but without any additional weightage or consideration on price)

S No.	Description - BHEL's Requirement	Specified	Offered	Remarks
	Manual Run/ Stop switch	Vendor to Confirm		
	Panel lamp/ lamp test switch	Vendor to Confirm		
	operator adjustment for time delay start/stop	Vendor to Confirm		
	operator adjustment for alternator voltage/ frequency	Vendor to Confirm		
2.3.2	Metering/ Monitoring	-		
	Lubricating oil Pressure	Vendor to Confirm		
	Engine/ Coolent Temperature	Vendor to Confirm		
	Diesel level indicator	Vendor to Confirm		
	Engine speed	Vendor to Confirm		
	Hours run	Vendor to Confirm		
	Battery Voltage	Vendor to Confirm		
	Current	Vendor to Confirm		
	voltage	Vendor to Confirm		
	KVA	Vendor to Confirm		
	KWH	Vendor to Confirm		
	frequency	Vendor to Confirm		
2.3.3	Protection/Warning	-		
	Common Shutdown	Vendor to Confirm		
	High Coolant temp warning and shutdown	Vendor to Confirm		
	Low lube oil pressure warning and shutdown	Vendor to Confirm		
	Overspeed Shutdown	Vendor to Confirm		
	Over current	Vendor to Confirm		
	Over voltage	Vendor to Confirm		
	Under Voltage	Vendor to Confirm		
	Over & under Hz.	Vendor to Confirm		
2.4	AMF Panel	-		
2.4.1	The control panel body will be fabricated out of 14-18 SWG MS Sheet. Panel will be suitable for floor mounting, indoor installation for placement outside the Acoustic Enclosure(Distance within 03 Mtrs from acoustic enclosure). Panel enclosure shall be in dust and vermin proof enclosure. Cabling/Wiring/control cabling of Panel with DG shall be done with copper conductor of appropriate size. Cables are ferruled for proper maintenance/checking/wiring of panel. Detachable cable gland plates should be provided. AMF panel shall have all the necessary contactors, indicating lights, push buttons.	Vendor to Confirm		-
2.4.2	The panel shall comprise in details of the following:	-		
2.4.2.1	Microprocessor based EDO ACB with O/L, S/C, U/V release along with protection CTs, relays etc.	Vendor to Confirm		
2.4.2.2	Digital Multifunction Meter along with required metering CTs etc.	Vendor to Confirm		
2.4.2.3	Auto,manual selector switch	Vendor to Confirm		
2.4.2.4	Emergency stop	Vendor to Confirm		
2.4.2.5	On delay timer	Vendor to Confirm		
2.5	Acoustic Enclosure	-		



Bharat Heavy Electricals Limited

Enquiry No. :

Due Date :

Supplier's Ref.:

Date :

Part A (Techno-Commercial Bid)

Section IV

Specification cum Compliance Certificate for 320 KVA SILENT DIESEL GENSET

Note:-

1. The 'Offered' Column and where applicable, the 'Deviations' & 'Remarks' Column of this format shall be filled in by the Bidder and submitted along with the offer. Inadequate / incomplete, ambiguous or unsustainable information against any of the clauses of the specifications / requirements shall be treated as non-compliance.

2. The offer and all documents enclosed with offer should be in English language only.

Name & Address of the supplier:

Telephone No.

Fax No.

e-mail :

Scope: Design, manufacture, supply, installation, testing & commissioning of 320 KVA SILENT DIESEL GENSET complying with the following specifications.

(Offers of bidders offering higher rating DG set against requirement of 320 KVA shall be acceptable subject to meeting other requirement of tender but without any additional weightage or consideration on price)

S No.	Description - BHEL's Requirement	Specified	Offered	Remarks
2.5.1	The enclosure shall be in modular construction with the provision to assemble and dismantle easily at site. The enclosure may be dispatched in dismantled condition.	Vendor to Confirm		
2.5.2	The enclosure is fabricated out of CRCA M.S. sheet of 14-16 SWG.	Vendor to Confirm		
2.5.3	The sheet metal components are hot dipped seven tank pretreated.	Vendor to Confirm		
2.5.4	Enclosure is polyester based powder coated (inside as well outside).	Vendor to Confirm		
2.5.5	Nut, bolts & hardwares are Zinc coated or of S.S.	Vendor to Confirm		
2.5.6	The doors are gasketed with EPDM gaskets to avoid leakage of sound.	Vendor to Confirm		
2.5.7	The door handles are lockable type.	Vendor to Confirm		
2.5.8	Specially designed attenuators are provided to control sound at air entry to the container and exit from the container.	Vendor to Confirm		
2.5.9	Adequate ventilation is provided to meet air requirement for combustion and heat removal.	Vendor to Confirm		
2.5.10	Temperature of enclosure does not exceed beyond 5-7°C of ambient temp.	Vendor to Confirm/specify		
2.5.11	The acoustic enclosure shall meet requirements of present applicable latest CPCB (India) norms & shall be suitable to suit Ministry of Environment and Forest (MOEF).	Vendor to Confirm		
2.6	Fuel Tank	-		
2.6.1	Fabricated from minimum 14-16 SWG sheet metal	Vendor to Confirm		
2.6.2	Base rail with integral fuel tank provided with drain plug for drainage and air vent /breather and inlet and outlet connection with cleaning provision (Man hole)	Vendor to Confirm		
2.6.3	Capacity shall be min. 450 ltr	Vendor to specify		
2.6.4	Inbuilt Base Frame mounted fuel tank with fuel level indicator	Vendor to Confirm		
2.6.5	Fuel consumption @ 75% load with Radiator & Fan	Vendor to specify		
2.6.6	Fuel consumption @ 100% load with Radiator & Fan	Vendor to specify		
2.7	Routine Inspection test for following shall be carried out on DG by supplier as per applicable standards to be witnessed by BHEL before dispatch (all testing charges shall be borne by supplier):	-		
2.7.1	Operational & Functional Test	Vendor to Confirm		
2.7.2	Insulation Test	Vendor to Confirm		
2.7.3	HV Test	Vendor to Confirm		
2.7.4	Load Test (at 100% load for one hour and at 10% overload for one hour).	Vendor to Confirm		
3.0	Installation and Commissioning of DG at BHEL works (Civil foundation work by BHEL)			
3.1	The installation includes installation of DG set including fixing of radiator, cooling fans, first filling of Lubricating oil & coolant, fixing of exhaust system, vibration dampners(AVM pads), connection of cables, connection of earthing system (earth pits & earthing strip shall be provided by BHEL), installation of acoustic chamber and any other job required to be carried out for installation of the DG SET at BHEL works. Unloading & shifting by BHEL in presence of supplier.	Vendor to Confirm		
3.2	Successful working of full capacity of the DG SET by the supplier shall be considered as part of commissioning.	Vendor to Confirm		
3.3	Tools, Tackles, instruments and other necessary equipments required to carry out all above activities should be brought at installation site by the supplier on returnable basis.	Vendor to Confirm		
3.4	Commissioning spares if required for commissioning of the DG within stipulated time, shall be brought by the supplier on returnable basis.	Vendor to Confirm		



Bharat Heavy Electricals Limited

Enquiry No. :

Due Date :

Supplier's Ref.:

Date :

Part A (Techno-Commercial Bid)

Section IV

Specification cum Compliance Certificate for 320 KVA SILENT DIESEL GENSET

Note:-

1. The 'Offered' Column and where applicable, the 'Deviations' & 'Remarks' Column of this format shall be filled in by the Bidder and submitted along with the offer. Inadequate / incomplete, ambiguous or unsustainable information against any of the clauses of the specifications / requirements shall be treated as non-compliance.

2. The offer and all documents enclosed with offer should be in English language only.

Name & Address of the supplier:

Telephone No.


Fax No.

e-mail :

Scope: Design, manufacture, supply, installation, testing & commissioning of 320 KVA SILENT DIESEL GENSET complying with the following specifications.

(Offers of bidders offering higher rating DG set against requirement of 320 KVA shall be acceptable subject to meeting other requirement of tender but without any additional weightage or consideration on price)

S No.	Description - BHEL's Requirement	Specified	Offered	Remarks
3.5	Portion, if any, of the DG SET, accessories and other supplied items where paint has rubbed off or peeled during transit or installation should be repainted and merged with the original surrounding paint by the vendor. For this purpose, the vendor should supply sufficient quantity of touch-up paint of various colours of paint used.	Vendor to Confirm		
3.6	Training			
3.6.1	Demonstration of all features of the equipment, control system & accessories & training of BHEL operators after installation at BHEL site for efficient and effective use of the equipment by supplier after commissioning of equipment.	Vendor to Confirm		
4.0	Packing & Transportation			
4.1	Packing & transportation shall be done for all items of complete machine with all Accessories and other supplied items to avoid any damage/loss. When machine is despatched, all small loose items shall be suitably packed in boxes. Any loss/damage occurred during transit/unloading, then same shall be borne by supplier.	Vendor to Confirm/specify		
5.0	Guarantee			
5.1	Guarantee for 12 months from the date of acceptance of the equipment after I&C at BHEL works. During Guarantee period, at least 2 visits per year and/or whenever called by BHEL (within 48 hours of call) by the service engineer of the supplier to be made & the parts, items, spares etc. needing replacement to be replaced by the supplier free of cost. In support a Performance Bank Guarantee of 10% of Basic Value of P.O. valid for 12 months from the date of commissioning will have to be furnished by the supplier	Vendor to Confirm/specify		
6.0	Drawings and documents to be furnished by the tenderer			
	Following documents (Hard copies) in English language should be supplied along with the machine. Only originals shall be supplied. Photocopies will not be accepted.	Vendor to Confirm		
6.1	Along with the offer			
6.1.1	General Technical leaflets/details of DG set. Test report of DG set conforming to CPCB-II norms from CPCB accredited laboratory.	Vendor to Confirm		
6.2	After placement of order - 03 sets			
6.2.1	Outline dimensional drawing showing the general arrangement and indicating the space required for detachable type cable end box, base dimension details, details of foundation, etc.	Vendor to confirm		
6.2.2	Terminal arrangement, control schematic and wiring diagram, flow diagram of the cooling system.	Vendor to confirm		
6.2.3	Drawings of major components & other relevant drawing or data necessary for satisfactory installation.	Vendor to confirm		
6.2.4	Manufacturer's Test Certificate of Engine & Alternator	Vendor to confirm		
6.2.5	Test Certificates of DG & BHEL inspection report.	Vendor to confirm		
6.2.6	Operation and maintenance manual	Vendor to Confirm		
6.2.7	Latest Price List of recommended standard/essential mechanical, electrical and electronic accessories & spares for 5 years (including 12 month's Guarantee period) for trouble free operation to be provided by vendor	Vendor to agree		
7.0	General			
7.1	Length x Width x Height of assembled DG Set with acoustic enclosure	Vendor to specify		
7.2	Dry weight of DG SET	Vendor to specify		

	Bharat Heavy Electricals Limited	Enquiry No. :		
		Due Date :		
		Supplier's Ref.:		
		Date :		
Part A (Techno-Commercial Bid)		Section IV		
Specification cum Compliance Certificate for 320 KVA SILENT DIESEL GENSET				
Note:-				
1. The 'Offered' Column and where applicable, the 'Deviations' & 'Remarks' Column of this format shall be filled in by the Bidder and submitted along with the offer. Inadequate / incomplete, ambiguous or unsustainable information against any of the clauses of the specifications / requirements shall be treated as non-compliance.				
2. The offer and all documents enclosed with offer should be in English language only.				
Name & Address of the supplier:				
Telephone No.				
Fax No.				
e-mail :				
Scope: Design, manufacture, supply, installation, testing & commissioning of 320 KVA SILENT DIESEL GENSET complying with the following specifications. (Offers of bidders offering higher rating DG set against requirement of 320 KVA shall be acceptable subject to meeting other requirement of tender but without any additional weightage or consideration on price)				
S No.	Description - BHEL's Requirement	Specified	Offered	Remarks
7.3	The electrical components used shall be from reputed international makes such as Siemens / Telemecanique / Merlin Gerin / GE/ ABB / Schenider and shall be in accordance with DIN/IEC Standards.	Vendor to Confirm/specify		
8.0	All other items not specified here but, necessary for safe, satisfactory and uninterrupted operation of D.G. set shall be supplied & installed by the supplier	Vendor to Confirm		
9.0	The design and operational features of the equipment offered shall also comply with the provisions of latest issue of the Indian Electricity Rules and other statutory regulations	Vendor to Confirm		
NOTE:(1) BIDDERS MAY VISIT BHEL-CFP SITE FOR ACTUAL SITE CONDITIONS BEFORE SUBMISSION OF OFFER (2) Offers with deviation to BHEL specifications, terms & conditions of tender enquiry and/or incomplete offers are liable to be rejected. (3) Bidders must submit their offer in prescribed format Annexure-A(Sections I-IV) & Annexure-B, otherwise offer shall be liable for rejection.				

Signature & Seal of Bidder