

SPECIAL CONDITION ANNEXURE - A

PR No. 125310602 dated 22.05.2019

1. Two-part bid. Open tender to be floated.
2. The intended items are required for GHAVP 1 & 2 (700MWe SG) project site.
3. **End Use and End User Certificates will not be provided by BHEL.**
4. Supply of Stainless Tubes as per DIN EN 10216-5 1.4550/1.4571 and attached technical specification **PC-M-961 Rev.01**. Supplier to confirm.
5. Supplier to give clause by clause confirmation for all clauses mentioned in technical specification PC-M-961 Rev.01. Deviations shall be mentioned in the offer itself.
6. Special requirement as given in Clause 5.0 of PC-M-961 Rev.01 "The cobalt content in the SS materials shall not exceed 0.03%" is **NOT APPLICABLE** for these tubes.
7. For offer acceptance suppliers should have the capability and experience to produce the items as per the quality standards intended in NPCIL technical specification (**PC-M-961 Rev.01**). **Supplier should have supplied the items for Nuclear application/Nuclear Power Corporation of India Limited/any other nuclear power station.** As a documentary proof of supplier's experience in manufacturing the items, Signed Test Certificates, Shipping release with specifications for previous supplies with details of Customer, Third Party Inspection Agency etc. shall be submitted along with offer.
8. Offers received will be evaluated by BHEL and NPCIL. Final acceptance of the offers will be based on NPCIL recommendation.
9. Supplier has to provide acceptance for the NPCIL Approved Generic QAP furnished by BHEL.
10. Supplier has to submit Quality Plan in line with the Generic Approved Quality Plan provided by BHEL along with the related procedures and documents as per QAP for approval. The production clearance will be provided only after approval of Quality Documents.
11. Supplier has to submit Quality Assurance Plan (QAP) and related test procedures and documents as per QAP for approval.
12. The actual production of material is permitted only after approval of Quality Assurance Plan (QAP) and test procedures by BHEL and NPCIL.
13. Inspection agency for imports are BHEL & NPCIL or NPCIL approved third party inspection (TPI) agency. TPI inspection charges to be quoted separately in offer.
14. Inspection agency for indigenous supply are BHEL and NPCIL.
15. For indigenous supply, chemical composition and mechanical tests to be carried out in NABL accredited laboratory only.
16. Supplier shall submit Test Certificates of finished material for our review. Dispatch clearance will be given after acceptance of Test Certificates by BHEL & NPCIL.
17. Three sets of documents containing (i.) Test Certificates and respective test reports (ii.) Copies of the approved quality documents and test procedure, (iii.) DCR and (iv.) Drawing etc. to be provided along with the supply of raw material.

pg. 1

Bithu
22/05/19

John

Denkatsan

M. PALANIVELU

Sr. Manager

Plant Eng & Sub. Contg / ATP
BHEL, TRICHY - 620 014.

PRAVIRAJ. S. PITHE

Sr. Engineer

Advanced Technology Products
BHEL, TRICHY - 620 014