



DOCUMENT TITLE

KKS NUMBERING PHILOSOPHY

1X800MW KOTHAGUDEM

KKS NUMBERING PHILOSOPHY

For identifying (tagging) an instrument / equipment in Power plant KKS numbering scheme is used. The purpose is to assign a unique number to every equipment in the power plant. For C&I equipment unique number are to be provided up to the signal level so that a unique number Input / Output exist in DCS for every signal.

Normally KKS number is a 10 digit alpha-numeric code and is typically split into the following:

X	X	X	A A Y			Y B B	B		
---	---	---	-------	--	--	-------	---	--	--

First three digits indicate the Sub-System. The Code for the major system are given as per **Annexure-1**.

Fourth and Fifth digits are the **Numerical Keys at System Code Level** and used to distinguish between main systems having same Alpha Codes.

Sixth and Seventh digits are the **Equipment / Apparatus / Measuring Circuit Code**. The code of various Equipment / Apparatus / Measuring Circuit is shown in **Annexure-2**

Eight, Nine and tenth digits are the **Numerical Keys at Equipment / Apparatus / Measuring Circuit Code** and used to distinguish between various instruments in the same sub-group. Numerical keys at System / Equipment / Apparatus / Measuring Circuit is shown in **Annexure-3**.



DOCUMENT TITLE

KKS NUMBERING PHILOSOPHY

1X800 MW KOTHAGUDEM

ANNEXURE-1**List of System / Sub-System Codes used in Power Plant:**

- 1) Compressed air system : QEA, QEC
- 2) Ventilation System : SAA TO SAZ
- 3) Fire Detection & Protection System + Fire Water pumps : SGM, SGN, SGO, SGP
- 4) Sewage Treatment : SJA TO SJZ
- 5) Pre-treatment Plant : GBI, GBM, GBV
- 6) RO DM Plant : GCI, GCM, GBV

ANNEXURE-2**Standard Equipment Codes:**

AA	Valves including drives, also hand operated
AB	Seclusions, Lock, Gates, Doors
AC	Heat Exchanger
AE	Turning, Driving, Lifting equipment
AF	Continuous conveyors, Feeders
AG	Generator Units
AH	Heating and Cooling Units
AK	Pressing and Packaging equipment
AM	Mixer, Stirrer
AN	Blower, Air Pumps / Fans, Compressor Units
AP	Pump Units
AT	Purification, Drying, Filter
AV	Combustion Equipment e.g. grates

Standard Apparatus Codes:

BB	Vessels and Tank
BF	Foundation
BG	Boiler Heating Surfaces
BN	Injector, Ejector
BP	Flow and throughput limitation equipment (Orifice)
BQ	HOLDERS, Carrying Equipment, Support
BR	Piping, Ducts, Chutes, Compensator
BS	Sound Absorber
BU	Insulations, Sheatings



DOCUMENT TITLE

KKS NUMBERING PHILOSOPHY

1X800 MW KOTHAGUDEM

Standard Measuring Circuits Codes:

CD	Density
CE	Electrical Quantities
CF	Flow, throughput
CG	Distance, Length, Position
CK	Time
CL	Level
CM	Humidity
CQ	Analysis (SWAS)
CS	Speed, Velocity, Frequency
CT	Temperature
CY	Vibration, Expansion

ANNEXURE-3**Numerical Keys****A) Numerical Keys at System Code Level**


- i) Use 10, 20, 30, To distinguish between main systems having same Alpha Codes. Examples:
 - a) Main Steam (Left) and Main Steam (Right)
 - b) BFP – A/B/C
 - c) ID Fan – A/B, FD Fan A/B, AH – A/B
- ii) For branch off from main system path having code say 10, keep the same alpha code and use 11, 12, 13 etc. Similarly for other branch off from main system path having code say 20, keep the same alpha code and use 21, 22, 23 etc and shall carry on further in the same way.
- iii) If the branch off from main system / sub system path is used for some other system, where different alpha codes can be applied, then in that case the said branch line will be designated by the alpha codes of the system to which it is providing the input.

B) Numerical keys at Equipment Code level:

There are three numerical keys available for each type of equipment code. Following has been agreed upon considering present practice, better flexibility and ease in sorting.

- i) Valves and Dampers --- *Equipment Code – AA*

N1N2 N3

	DOCUMENT TITLE
	KKS NUMBERING PHILOSOPHY

1X800 MW KOTHAGUDEM

Motorised (<i>on/off duty</i>)	-	0	01 to 50
Motorised (<i>inching duty</i>)	-	0	51 to 99
Pneumatic (Control)	-	1	01 to 50
Motorised (<i>thyrestor Control</i>)	-	1	51 to 99
Sol. Operated	-	2	01 to 99
(Open / Close duty (Valves, NRVs, Gate))			
Hydraulic	-	3	01 to 99
NRV (Without actuation)	-	4	01 to 99
Manual	-	5	01 to 99
Manual	-	6	01 to 99
Relief & Safety Valves	-	7	01 to 99
Reserve	-	8	01 to 99
Reserve	-	9	01 to 99

ii) **Field Instruments**





Field Transmitters & Analog Signals	-	0	01 to 99
Field Switches & Binary Signals	-	1	00 to 99
PG Test Point	-	4	00 to 99
Gauges	-	5	00 to 99
Automatic Turbine Tester (ATT)-HWR	-	2	00 to 99


(Reserved for protection Signals used by Hardwar)

Example of Numerical Key Usage:

In line with the philosophy adopted for Valves / Dampers /instruments etc. pumps and fans in the main systems (having different system code) can be numbered as AP/N100 and as AP/N101, 102, Where system code is same.

INSTRUMENT STUB DETAILS

					CUSTOMER:  TELANGANA STATE POWER GENERATION CORPORATION LTD TELANGANA, INDIA 5 x 800 MW YADADRI TPS, UNIT # 1 TO 5									
					CONSULTANT:  TATA CONSULTING ENGINEERS LIMITED BANGALORE, INDIA									
JOB NO. 417 STATUS CONTRACT DISTRIBUTION					 BHARAT HEAVY ELECTRICALS LTD POWER SECTOR PROJECT ENGINEERING MANAGEMENT NOIDA									
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED it must not be used directly or indirectly in any way detrimental to the interest of the company.										DEPT CODE 	NAME DRN AKS DESN AKS CHD RKR APPD SSB	SIGN _____ _____ _____ _____ _____ _____ _____	DATE 20.01.18 20.01.18 20.01.18 20.01.18	
REV.	DATE	ALTD	CHD	APPD	REV.	DATE	ALTD	CHD	APPD	TITLE INSTRUMENT STUB DETAILS				
										DEPT. SIGN	SCALE 	DRAWING NO. PE-DG-417-145-I101		
										SHEET 1 OF 6	REV. 00			

**NOTE :**


1. MATERIAL OF THE BOSS AND NIPPLE SHALL BE THE SAME AS THE PIPE INTO WHICH IT IS WELDED AND CONFORM TO ANSI B16.11.
2. THE LENGTH OF NIPPLE SHALL BE 250 MM.
3. THE OTHER END OF THE NIPPLE SHALL BE SOCKET WELDED WITH 1/2" GLOBE VALVE OF MATERIAL AS PER ANSI B 31.1.
4. TWO ISOLATION VALVES ARE TO BE USED FOR PRESSURE EXCEEDING 40 Kg/Cm2.
5. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
6. EDGE HOLE MUST BE CLEAN AND SQUARE OR ROUNDED SLIGHTLY(1/64" RADIUS) FREE FROM BURRS, WIRE EDGES OR OTHER IRREGULARITIES.



TITLE : 5 x 800 MW YADADRI TPS
 STD INSTRUMENT STUB
 DETAILS
 PRESSURE STUB

DRG. NO.
 PE-DG-417-145-1101
 REV. 00
 SH. 02 OF 06

SYSTEM PRESS < 60Kg/Cm2 & SYSTEM TEMP < 425 Deg C, Nb15 , CL3000

**NOTE :**


1. MATERIAL OF THE BOSS AND NIPPLE SHALL BE THE SAME AS THE PIPE INTO WHICH IT IS WELDED AND CONFORM TO ANSI B16.11.
2. THE LENGTH OF NIPPLE SHALL BE 250 MM.
3. THE OTHER END OF THE NIPPLE SHALL BE SOCKET WELDED WITH 1" GLOBE VALVE OF MATERIAL AS PER ANSI B 31.1.
4. TWO ISOLATED VALVES ARE TO BE USED.
5. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
6. EDGE HOLE MUST BE CLEAN AND SQUARE OR ROUNDED SLIGHTLY(1/64" RADIUS) FREE FROM BURRS, WIRE EDGES OR OTHER IRREGULARITIES.



TITLE : 5 x 800 MW YADADRI TPS
 STD INSTRUMENT STUB
 DETAILS
 PRESSURE STUB

DRG. NO.
 PE-DG-417-145-1101
 REV. 00
 SH. 03 OF 06

SYSTEM PRESS > 60Kg/Cm² & 425 Deg C < SYSTEM TEMP <= 500 Deg C , Nb25 , CL3000/6000


**NOTE :**

1. MATERIAL OF THE BOSS AND NIPPLE SHALL BE THE SAME AS THE PIPE INTO WHICH IT IS WELDED AND CONFORM TO ANSI B16.11.
2. THE LENGTH OF NIPPLE SHALL BE 250 MM.
3. THE OTHER END OF THE NIPPLE SHALL BE SOCKET WELDED WITH 1" GLOBE VALVE OF MATERIAL AS PER ANSI B 31.1.
4. TWO ISOLATED VALVES ARE TO BE USED.
5. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
6. EDGE HOLE MUST BE CLEAN AND SQUARE OR ROUNDED SLIGHTLY(1/64" RADIUS) FREE FROM BURRS, WIRE EDGES OR OTHER IRREGULARITIES.




TITLE : 5 x 800 MW YADADRI TPS
 STD INSTRUMENT STUB
 DETAILS
 PRESSURE STUB
 SYSTEM TEMP > 500 Deg C , Nb25 , CL9000

DRG. NO.
 PE-DG-417-145-1101
 REV. 00
 SH. 04 OF 06



TEMPERATURE STUB FOR STRAIGHT IMMERSION



TEMPERATURE STUB FOR SLANT IMMERSION

NOTE :


1. MATERIAL OF THE BOSS SHALL BE THE SAME AS THE PIPE INTO WHICH IT IS WELDED.
2. LENGTH OF THE STUB (L) SHALL BE 64/45 mm DEPENDING UPON PIPE SIZE, AS PER CORPORATE STD. AA 7326102.(FOR PIPE OD 88.9 mm TO 159 mm STUB HEIGHT SHALL BE=64mm & FOR PIPE OD \geq 219.1mm STUB HEIGHT SHALL BE=45mm)
3. STRAIGHT IMMERSION STUBS SHALL BE USED FOR PIPE OD'S 168.3 mm & ABOVE. THE STUB HEIGHT FOR PIPE OD 168.3 mm TO <219.1 mm SHALL BE 64 mm.
4. SLANT IMMERSION STUBS SHALL BE USED FOR PIPE OD'S 88.9 mm TO 159 mm.
5. FOR MAIN PIPE OD'S 88.9 mm & BELOW SUITABLE EXPANDER SHALL BE USED.
6. PLEASE REFER SHEET-6 FOR THERMOWELL INSTALLATION.



TITLE : 5 x 800 MW YADADRI TPS
STD INSTRUMENT STUB
DETAILS


TEMPERATURE STUB

DRG. NO.
PE-DG-417-145-I101
REV. 00
SH. 05 OF 06




INSTALLATION TYPE-1

FOR MAIN PIPE OD 88.9mm to 159mm




INSTALLATION TYPE-2

FOR MAIN PIPE OD BELOW 88.9mm



INSTALLATION TYPE-3

FOR MAIN PIPE OD 88.9mm & BELOW



INSTALLATION TYPE-4

FOR MAIN PIPE OD 168.3mm & ABOVE



TITLE : 5 x 800 MW YADADRI TPS

STD INSTRUMENT STUB
DETAILS

THERMOWELL INSTALLATION

DRG. NO.
PE-DG-417-145-1101
REV. 00
SH. 06 OF 06



TITLE: 5X800 MW YADADRI THERMAL POWER STATION	SPECIFICATION NO. PE-TS-417-155A-A001	
	SECTION : III	
	TECHNICAL SPECIFICATION FOR CONDENSATE POLISHING UNIT	
	REV. NO. 00	DATE :

SECTION III




TITLE: 5X800 MW YADADRI THERMAL POWER STATION	SPECIFICATION NO. PE-TS-417-155A-A001	
	SECTION : III	
TECHNICAL SPECIFICATION FOR CONDENSATE POLISHING UNIT	REV. NO. 00	DATE :

SCHEDULE OF PRE-BID CLARIFICATION

All clarification from the Technical Specification shall be filled in by the BIDDER clause by clause in this format only.

VOLUME	SECTION	CLAUSE NO.	PAGE NO.	SPECIFICATION REQUIREMENT	CLARIFICATION	REASONS FOR CLARIFICATION


Note: Bidder to furnish all the pre bid in the above indicated pre bid clarification format only. General Pre bid clarification will not be considered.

	TITLE:	SPECIFICATION NO. PE-TS-417-155A-A001	
	5X800 MW YADADRI THERMAL POWER STATION	SECTION : III	
	TECHNICAL SPECIFICATION FOR CONDENSATE POLISHING UNIT		
		REV. NO. 00	DATE :

COMPLIANCE CUM CONFIRMATION SCHEDULE

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate and furnishing same with the offer:

- a.) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions/ deviations with regard to same.
- b.) QP/ test procedures shall be submitted in the event of order based on the guidelines given in the specification & QP enclosed therein. QP will be subject to BHEL/Customer approval in the event of order & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc. The charges for 3rd party inspection (Lloyds, TUV or equivalent) for imported components shall be included in the base price of the equipment by the bidder.
- c.) All drawings/data – sheets etc. to be submitted during contract shall be subject to BHEL/Customer review/ approval. GA drawings, as submitted with offer at tender stage are for reference purpose only and shall be subject to approval during contract stage.
- d.) There are no other deviations with respect to specification other than those furnished in the 'Schedule of Deviations'.
- e.) The offered materials shall be either equivalent or superior to those specified. Also for components where material is not specified it shall be suitable for intended duty, materials shall be subject to approval in the event of order.
- f.) The commissioning spares (if any) are supplied on 'As Required Basis' & prices for same included in the base price (If bidders reply to this is "No commissioning spares are required" and if some spares are actually required during commissioning same shall be supplied by bidder without any cost to BHEL).
- g.) All sub vendors shall be subject to BHEL/CUSTOMER approval.
- h.) Any special tools & tackles, if required, shall be in bidder's scope.
- i.) Demonstration parameters shall stand valid till the satisfactory completion of demonstration test and its acceptance by BHEL/Customer.

	TITLE:		SPECIFICATION NO. PE-TS-417-155A-A001	
	5X800 MW YADADRI THERMAL POWER STATION		SECTION : III	
	TECHNICAL SPECIFICATION FOR CONDENSATE POLISHING UNIT			

DECLARATIONS

Icertify that all the technical data and information pertaining to this specification are correct and are true representation of the equipment/system covered by our format proposal number Dated and there is no deviation to the specification.

I hereby certify that I am duly authorized representative of the Bidder's company whose name appears above my signature.

Bidders Company Name

Authorized representative's Signature

Name

Bidder's Name The bidder hereby agrees to fully comply with the requirements and intent of this specification for the price indicated

